



বাংলাদেশ পাওয়ার ইকুইপমেন্ট ম্যানুফেকচারিং কোম্পানী লিঃ
BANGLADESH POWER EQUIPMENT MANUFACTURING COMPANY LTD.

ISO 9001:2015 & OHS 45001:2018 Certified

Memo No: BPEMC/Technical/2024/1666


Date: 14/12/2024

Notice

**Subject: Minutes of pre-tender meeting and clarifications of queries against tender invitation
Ref. No: BPEMC/Technical/2024/1627; Date: 04/12/2024.**

In response to the queries received from prospective bidder(s) within the stipulated time as decided in the pre-tender meeting held on 11.12.2024, the respective clarifications/Amendments from BPEMC is attached herewith.

These clarifications/Amendments shall be treated as an integral part of the tender document.


14/12/24
(Md. Salim Bhuiyan)

Chief Executive Officer (Addl. Charge), BPEMC

Copy :

1. Chief Financial Officer (Addl. Charge), BPEMC, Nikunja-2, Khilkhet, Dhaka.
2. General Manager (Technical), BPEMC, Nikunja-2, Khilkhet, Dhaka.
3. Office Copy.

Minutes of Pre-Tender Meeting and Clarifications of Queries

Tender Name: For Procurement of Supply of Junction Box and all necessary accessories for Data Concentrator Unit (DCU) installation.
 Invitation Ref No: BPEMC/Technical/2024/1627; Dated: 04.12.2024

Queries No	Package No	Tender Clause/Section	As published in Tender Notice/ Document	Queries	Response of BPEMC
01		Section-8 Drawing		At page No: 35, As per drawing Which grade sheet to use for DCU box?	According to the drawing, 20 Standard Wire Gauge (SWG) grade sheet must be used for DCU box.
02		Section-8 Drawing		At page No: 35, As per drawing what is the diameter of the nut-bolt sheet to use for DCU box?	According to the drawing, the diameter of the bolt will be 12 mm and the length will be 50 mm. SS grade (304) must be used for nut bolts.
03	Package No: G-2	Section-8 Drawing		At page No: 35, As per drawing what is the diameter of the pole clamp and Which grade sheet to use for pole clamp and DCU Box clamp.	According to the drawing, the diameter of the pole clamp will be 11 inch and 16 Standard Wire Gauge (SWG) grade sheet must be used for pole clamp and DCU Box clamp.
04		Section-6 Schedule of Requirements	Point of delivery: 9/F,Sena Kalyan Commercial Complex (4 th Floor), Tongi,Gazipur or DESCO Central Store, Mirpur,Dhaka.	Shall the goods to be delivered only BPEMC or DESCO or both?	The supplier will deliver the goods at BPEMC factory (9/F,Sena Kalyan Commercial Complex (4 th Floor),Tongi, Gazipur) first. After completion of PDI by DESCO, the supplier will deliver the goods from BPEMC factory (9/F,Sena Kalyan Commercial Complex,Tongi,Gazipur) to DESCO Central Store, Mirpur, Dhaka.


 - (Md. Salim Bhuiyan)
 Chief Executive Officer, BPEMC